

GOVERNMENT OF TELANGANA STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT



From

The District fire officer,

Yadadri Bhongir Division.

To.

MURKI SREENIVAS.

D.NO. 4-166/2.

GUDUR VILLAGE.

BIBINAGAR MANDAL.

VADADRI BHUVANAGIRI DISTRICT.

and the
E
Н

Ack. No.473430002022 Dated:03/01/2023

Sir,
Sub:

TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE
DEPARTMENT - Yadadri Bhongir Division. Renewal of No
Objection Certificate for Occupancy to the Non Multi storeyed
Building of SHLOKA A BIRLA SCHOOL, D.NO. 4-166/2, GUDUR

Building of SHLOKA A BIRLA SCHOOL, D.NO. 4-166/2, GUDUR VILLAGE, BIBINAGAR MANDAL, YADADRI BHUVANAGIRI

DISTRICT/-Gudur/Bibinagar/Yadadri, - Regarding.

1. Acknowledgement No 473430002022

This Office NOC for Occupancy Ack/RC No.0001640/OOCU/YADADRI/2017

Ref: dt.03/01/2023

3. Non Multi storeved Building Inspection Committee Report,.

Ack. No. 473430002022, dt. 03/01/2023

本杂杂字字 李字字字字 李字字字本

- The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of SHLOKA A BIRLA SCHOOL, D.NO. 4-166/2, GUDUR VILLAGE, BIBINAGAR MANDAL, YADADRI BHUVANAGIRI DISTRICT/-Gudur/Bibinagar/Yadadri
- 2) The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with 1 Ground, 1 Floors, with a height of 8.00 Meters for EDUCATIONAL B-1 Schools up to senior secondary level Occupancy.
- 3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with 1 Ground, 1 Floors, with a height of 8.00 Meters for EDUCATIONAL B-1 Schools up to senior secondary level Occupancy

4) Open Spaces: The builder provided the following open spaces all around the building.

Side	Open spaces as per Noc occupancy	Open spaces provided now
	the control of the co	50.00
South	6.00	50.00
1	nng a samonif an ina ina na na paga na kenganta ina ang ani na kengangan akaumang kengan, ini pransabi asaman kac COO	12.90
The control of the co		20.00
Gate Width As per Occupancy NOC	as per Noc occupancy	provided now
Entry gate width	4.50	6.0
Entry Gate Head Clearance	5.00	for game activated on a mineral particular activation in the best of the particular statements of the series parentless
Exit Gate Width	4.50	6.0
Exit Gate Head Clearance		5.00
	North South East West Gate Width As per Occupancy NOC Entry gate width Entry Gate Head Clearance Exit Gate Width	North South 6.00 East 6.00 West 6.00 West 6.00 Gate Width As per Occupancy NOC Entry gate width 4.50 Entry Gate Head Clearance Exit Gate Width 4.50

100	FET 8	The same
1	2 7 2 4 6 6 2 4	Distance

Sl. No.	Item / Description	as per Noc occupancy	provided now
1	Farthest point (Most Remote Point) With in a storey or a mezzapine[floor to the door to an Exit. DRINCIP school	30.00	25.56
2	The Dead end of the corridor length in exit access. (6 plus for Faucation 196	6.00	0.00

Fellul Author

6) Stair Cases (As per Occupancy NOC):

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to
i ·	luternal staircases	2.70		Ground	1st Floor
2	External staircases	2.40		Ground	1st Floor
3	External staircases	1.80		Ground	1st Floor
4	Internal staircases	240		Ground	1st Floor
5	External staircases	2.00		Ground	1st Floor

7) Means of Escape Floor Wise Details:

SLno.	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy		Means of escape required as per Occupancy NOC	Means escape available now
1	Groun d	2560,00	EDUCATIONAL B-1 Schools up to senior secondary level	640.00	11.30	11.30
2	lst Floor	2560.00	EDUCATIONAL B-1 Schools up to senior secondary level	640.00	11.30	11.30

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

Si.n	Floor Details	A		Automatic Sprinklers System	Manually Operated Electronic Fire Alarm System	Automate detection and alarm system
1	Ground	13.00	3.00	0.00	0.00	0.00
2	1st Floor	13.00	3.00	0.00	0.00	0.00

10) Fire Fighting Installations As per Occupancy NOC:

Fire Fighting System.	Required As per Occupancy NOC	Provided
Fire Extinguishers	26	52
First Aid Hose Reel	6	6
Capacity of Terrace Tank over Respective Tower Terrace in Litres	10000	10000
Pump capacity in LPM at the Terrace Tank level with min Pressure of 3.5 Kg/CM^2	450	450
No. of Terrace Tanks over Respective Tower in ltrs No. of Pumps at the Terrace Tank level with min pressure of 3.5 Kg/Cm ²		

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measres and there is no deficiencies.

12. Remarks:

approved as recommended by the inspection committee

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with SHLOKA A BIRLA

SCHOOL,D.NO. 4-166/2, GUDUR VILLAGE, BIBINAGAR MANDAL, YADADRI BHUVANAGIRI DISTRICT/-Gudur/Bibinagar/Yadadri

with a height of 8.00 Meters for EDUCATIONAL B-1 Schools up to senior secondary level Occupancy subject to the following conditions

SI No	Builder and Management Body	Occupant	Management Body and fire and security personnel
Controversion of the control of the	-a) All the fire protection arrangements shall be maintained in good condition as seen during inspection.	not be kept locked/blocked or	All the occupants must know the correct method of operation of the fire fighting systems installed ANA

Comme of the

Full To the second

ender statistischen Thimstatese	-b) Do's and Don'ts in case of fire shall be prominently displayed in enure outloing		
unit sphistoperanement strategic manual	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipment during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
A A A	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
A.	This No objection Certificate for occupancy is valid for Five year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.

This Renewal of No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Yours Sincerely, District fire officer. Yadadri Bhongir Division.

Copies to:

- i) The Management
- ii) Non Multi storeyed Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"

PRINCIPAL

PRINCIPAL

School

School

School

Billa School

Billa School

School

Billa School

Billa School

School

Billa School

Billa School

School

Billa School

School

Billa School

FOR SAI BY AVANA EDUCATION A PORT OF SAI BY AVANA EDUCATION A PROPERTY OF SAI BY AVANA EDUCATION A PORT OF SAI BY AVANA EDUCATION A